Data Centre Size	Criteria
<1 MVA	➢ A De Minimus threshold applies to a data centre with an MIC lower than 1 MVA.
1 MVA > 10 MVA	➢ Data centres with an MIC greater than 1 MVA but lower than 10 MVA, are required to install an auto producer unit sufficient to cover the site's MIC (subject to de-rating) and which must participate in the Irish wholesale energy market. The requirements applicable to Renewable Generation (discussed in the table below) also apply.
> 10 MVA	➢ See table below.